

Title: Tensile Breaking Strength Test
with Conductor AAC Pansy

At the request of: EMTA KABLO SANAYI VE TİCARET A.Ş.
İstasyon Mahallesi İbişğa Caddesi No:4 34940 Tuzla – İstanbul,
Turkey

Test standard: EN 50182:2001

Place of test: RIBE Test Laboratory
Werk 2
Industriestr. 5
91126 Schwabach, Germany

Internal request for test: VA 16242 File: 1.2 Contents: 6 pages

Summary:

A Tensile Breaking Strength Test was carried out with a sample of conductor AAC Pansy received from the purchaser.

Failure load was 7,51 kN (102,9 % of the specified minimum breaking strength 7,3 kN).



Mario Dansachmüller
RIBE Engineering

Schwabach, 13 July 2016



Hans-Jörg Krispin
RIBE Engineering

Index

1. Test procedure	2
2. Result	2
Annex 1: Conductor data	4
Annex 2: Calibration certificate load cell	5

Richard Bergner
Elektroarmaturen GmbH & Co. KG
Sitz in Radebeul
Amtsgericht Dresden HRA 2857
Persönlich haftende Gesellschafterin:
Richard Bergner Elektroarmaturen Verwaltungs GmbH
AG Nürnberg HRB 14627

Geschäftsführer:
Frank A. Bergner
Thomas Dann

Hausanschrift:
Bahnhofstr. 8-16
91126 Schwabach
Germany

Telekommunikation:
Telefon +49 (0) 9122 / 87 -0
Telefax +49 (0) 9122 / 87 -1506
E-Mail elektroarmaturen@ribe.de

Bankverbindung:
Commerzbank Schwabach, Kto-Nr. 5 803 598, BLZ 760 400 61
UST-ID-Nr.: DE188368425

www.ribe.de

1. Test procedure

Characteristics of the conductor are given in Annex 1.

The conductor sample was prepared in line with the instructions given in EN 50182. Epoxy type end fittings were used. The length of the free conductor between end fittings was 10,35 m.

Measuring devices (calibration certificate see Annex 2):

Tensile load	Load cell 50 kN HBM U2, S.No. 89022
--------------	-------------------------------------

A screw-type tension device was used (constant rate of displacement per time). The rate of increase of load was such that 30 % minimum breaking strength (MBS) were reached after 41 seconds starting from a preload of 5 % MBS (0,37 kN). Temperature was 24,0 °C.

2. Result

The breaking strength of the conductor is determined by the load attained at which one or more wires of the conductor are fractured.

Total breakage of the conductor occurred at a load of 7,51 kN (102,9 % MBS) in the free span at a distance of approximately 2,5 m from one of the end fittings.




Fig. 1: Diagram load vs. time



Fig. 2: Total breakage of the conductor in the free conductor span approximately 2,5 m from one end fitting.

Annex 1: Conductor data

CODE NAME		PANSY				
STANDARD		ASTM B 231/B 231M – 04				
All Aluminum Conductor	Size/nominal sectional area	AWG / MCM	1			
	Aluminum strand	Number	7	Diameter	2.78	mm
	Calculated area	mm ²	42.49			
	Minimum breaking strength	kN	7.3			
	Outside diameter	mm	8.34			
	Standard weight	kg/km	116.6			
	Calculated resistance 20°C	D.C.	0.6755	Ohm/km	A.C. 50 Hz	Ohm/km
	Modulus of elasticity	Initial		N/mm ²	Final	60,000 N/mm ²
	Coefficient of linear expansion	Per °C	23 * 10 ⁻⁶			
	Length of each reel	m (+/- %2)	5,000			
	Reel type	mm*mm*mm	1000 * 500 * 660 (760)			
	Net weight per drum	kg	583			
	Gross weight per drum	kg	663			
	Grease weight	kg/km (+/-%20)				
	Grease type					
ALUMINUM WIRE	Diameter	mm	2.78			
	Ultimate tensile strength (before stranding)	N/mm ²	165			
	Conductivity at 20°C	% IACS	61			
<p>EMTA KABLO SANAYI VE TİCARET A.Ş. İstasyon Mahallesi İbizağa Caddesi No:4 34940 Tuzla – İstanbul Tel:(+90) 216 446 66 06 / Fax:(+90) 216 446 43 93 sales@emtaconductor.com - www.emtaconductor.com</p>						

Annex 2: Calibration certificate load cell

RIBE

Richard Bergner Elektroarmaturen GmbH + Co. KG

EEK

Page 1/2

Protocol

Cert_50kN_HBM_U2_89022_2016-07-12 12/07/2016

Calibration protocol according to DIN ISO 10012

Calibration protocol code Cert_50kN_HBM_U2_89022_2016-07-12

Devices calibrated:

Device 1:	Load Cell HBM U2
Serial No.:	89022
Device 2:	Measurement Amplifier HBM MGCplus / ML55B
Serial No.:	801197960/1
Device 3:	none
Serial No.:	none

Calibration reference device

Device 1:	Load Cell Hegewald&Peschke 1210-AF20kN
Serial No.:	545012
Calibration certificate:	1105RB2/2015 dated 05.11.2015

Measurement data:
Date of calibration:
Calibration carried out by:

Page 2
12/07/2016
H. Jung



CERT_50kN_113-04_2016-07-12.xlsx

