

Engineering Report

EB-16242-21



Title: Tensile Breaking Strength Test
with Conductor 242-AL1/39-ST1A (LA 280 HAWK)

At the request of: EMTA KABLO SANAYI VE TİCARET A.Ş.
İstasyon Mahallesi İbişğa Caddesi No:4 34940 Tuzla – İstanbul,
Turkey

Test standard: EN 50182:2001

Place of test: RIBE Test Laboratory
Werk 2
Industriestr. 5
91126 Schwabach, Germany

Internal request for test: VA 16242 File: 1.2 Contents: 5 pages

Summary:

A Tensile Breaking Strength Test was carried out with a sample of conductor 242-AL1/39-ST1A (LA 280 HAWK) received from the purchaser.

Failure load was 93,7 kN (110,3 % of the specified minimum breaking strength 84,89 kN).

Mario Dansachmüller
RIBE Engineering

Hans-Jörg Krispin
RIBE Engineering

Schwabach, 16 June 2016

Index

1. Test procedure	2
2. Result	2
Annex 1: Conductor data	4
Annex 2: Calibration certificate load cell	5

Richard Bergner
Elektroarmaturen GmbH & Co. KG
Sitz in Radebeul
Amtsgericht Dresden HRA 2857
Persönlich haftende Gesellschafterin:
Richard Bergner Elektroarmaturen Verwaltungs GmbH
AG Nürnberg HRB 14827

Geschäftsführer:
Frank A. Bergner
Thomas Dann

Hausanschrift:
Bahnhofstr. 8-16
91126 Schwabach
Germany

Telekommunikation:
Telefon +49 (0) 9122 / 87 -0
Telefon +49 (0) 9122 / 87 -1506
E-Mail elektroarmaturen@ribe.de

Bankverbindung:
Commerzbank Schwabach, Kto-Nr. 5 803 598, BLZ 760 400 61
UST-ID-Nr.: DE188368425

www.ribe.de

1. Test procedure

Characteristics of the conductor are given in Annex 1.

The conductor sample was prepared in line with the instructions given in EN 50182. Epoxy type end fittings were used. The length of the free conductor between end fittings was 12,19 m.

Measuring devices (calibration certificate see Annex 2):

Tensile load	Load cell 200 kN Lorenz K11, S.No. 28261
--------------	--

A screw-type tension device was used (constant rate of displacement per time). The rate of increase of load was such that 30 % minimum breaking strength (MBS) were reached after 1 minute 3 seconds starting from a preload of 5 % MBS. Temperature was 21,4 °C.

2. Result

The breaking strength of the conductor is determined by the load attained at which one or more wires of the conductor are fractured.

The first wire (aluminium wire of the outer layer) fractured at a load of 93,7 kN (110,3 % MBS) in the free span at a distance of 2,15 m from one of the end fittings. Maximum load obtained was 95,1 kN. The test was terminated after fracture of a total of six outer layer aluminium wires.




Fig. 1: Diagram load vs. time




Fig. 2: Diagram load vs. time




Fig. 3: Breakage of six outer layer aluminium wires in the free conductor span

Annex 1: Conductor data

EMTA CONDUCTOR & CABLE		SGS		UKAS WIRING 005		
CODE NAME			242-AL1/39-ST1A			
OLD CODE			LA 280 HAWK			
STANDARD			BS EN 50182_2001			
Aluminium Conductor Steel Reinforced	Size/nominal sectional area	mm ²	240			
	Aluminum strand	Number	26	Diameter	3,44	
	Steel strand(for ACSR only)		7		2,68	mm
	Calculated area	Alum.	241,6	mm ²	Total	281,1
		Steel	39,5			
	Minimum breaking strength	kN	84,89			
	Outside diameter	mm	21,80			
	Standard weight	Alum.	667,4	kg/km	Total	976,2
		Steel	308,8	kg/km		
	Calculated resistance 20°C	D.C.	0,1195		Ohm/km	
	Modulus of elasticity	Final	77.000		N/mm ²	
	Coefficient of linear expansion	Per °C	18.9 * 10 ⁻⁶			
	Lay ratio and Direction of lay	Alum.	Outer		Second	
			10 - 14	Right	10 - 16	Left
			Steel	16 - 26	Right	
	Length of each reel	m (+/- %2)	1.750			
	Reel type	mm*mm*mm	1500 * 700 * 750 (890)			
	Net weight per drum (without grease)	kg	1.708			
Gross weight per drum	kg	1.928				
Grease weight Acc. To BS EN 50182_2001*	kg/km (+/-%20)					
Grease type						
ALUMINIUM WIRE	Diameter	mm	3,44			
	Ultimate tensile strength	N/mm ²	165			
	Conductivity at 20°C	% IACS	61			
STEEL CORE WIRE	Diameter	mm	2,68			
	Ultimate tensile strength	N/mm ²	1.350			
	Stress at 1% extension	N/mm ²	1.140			
	Elongation in 250 mm	%	3,0			
	Galvanizing weight of coating	g/m ²	230			
	Torsion	turns	16			
EMTA KABLO SANAYI VE TİCARET A.Ş. İstasyon Mahallesi İbrişğa Caddesi No:4 34940 Tuzla – İstanbul Tel:(+90) 216 446 66 06 / Fax:(+90) 216 446 43 93 sales@emtaconductor.com - www.emtaconductor.com						

Annex 2: Calibration certificate load cell



Zentrum für Konstruktionswerkstoffe
Staatliche Materialprüfungsanstalt Darmstadt
Fachgebiet und Institut für Werkstoffkunde
Prof. Dr.-Ing. Matthias Oechsner



TECHNISCHE
UNIVERSITÄT
DARMSTADT

akkreditiert durch die / accredited by the

Deutsche Akkreditierungsstelle GmbH

als Kalibrierlaboratorium im / as calibration laboratory in the



Deutsche
Akkreditierungsstelle
D-K-11048-01-00

Deutschen Kalibrierdienst

DKD

Kalibrierschein

Calibration certificate

W 160272.3

1. Ausfertigung

Kalibrierzeichen
Calibration mark

L 1938
D-K- 11048-01-00
2016-02

Gegenstand Object	liegende 200 kN Zugprüfmaschine
Hersteller Manufacturer	Lorenz
Typ Type	K11
Fabrikat/Serien-Nr. Serial number	28261
Auftraggeber Customer	RIBE, Richard Bergner Elektroarmaturen GmbH & Co. KG Bahnhofstraße 8 - 16 91126 Schwabach
Auftrags-, Vertragsnummer	310513 vom 20.1.14 / W 620
Anzahl der Seiten des Kalibrierscheines Number of pages of the certificate	7
Datum der Kalibrierung Date of calibration	15.02.2016

Dieser Kalibrierschein dokumentiert die Rückführung auf nationale Normale zur Darstellung der Einheiten in Übereinstimmung mit dem Internationalen Einheitensystem (SI). Die DAkks ist Unterzeichner der multilateralen Übereinkommen der European co-operation for Accreditation (EA) und der International Laboratory Accreditation Cooperation (ILAC) zur gegenseitigen Anerkennung der Kalibrierscheine. Für die Einhaltung einer angemessenen Frist zur Wiederholung der Kalibrierung ist der Benutzer verantwortlich. This calibration certificate documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). The DAkks is signatory to the multilateral agreements of the European co-operation for Accreditation (EA) and of the International Laboratory Accreditation Cooperation (ILAC) for the mutual recognition of calibration certificates. The user is obliged to have the object recalibrated at appropriate intervals.

Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Auszüge oder Änderungen bedürfen der Genehmigung sowohl der Deutschen Akkreditierungsstelle als auch des ausstellenden Kalibrierlaboratoriums. Kalibrierscheine ohne Unterschrift haben keine Gültigkeit. This calibration certificate may not be reproduced other than in full except with the permission of both the German Accreditation Body and the issuing laboratory. Calibration certificates without signature are not valid.



Stempel Seal	Datum Date	Stellv. Leiter des Kalibrierlaboratoriums Deputy head of the calibration laboratory	Bearbeiter Person in charge
	16.02.2016	 Dipl.-Ing. (FH) A. Hecht	 Dipl.-Ing. V. Marzian

Staatliche Materialprüfungsanstalt Darmstadt
Grafenstraße 2, D-64283 Darmstadt

Mess- und Kalibriertechnik
kalibrierlabor@mpa-ifw.tu-darmstadt.de

Telefon: 06151 16-25144
Fax: 06151 16-25126